

Appendix B – Drainage Repairs & Improvements

Drainage Repairs & Improvements - Contact Officer Earl Bournier			
Road Name	Parish	Description of Works	Current Status
Harp Farm Road	Boxley	Existing soakaway unmaintainable due to location in field. Replacement soakaway(s) to be considered.	Works Completed.
Holmoaks	Maidstone	Maintenance to existing system to stop damage to footway in park	Works completed; however, system was damaged by severe weather 3 rd October. Further works therefore required.
Eccleston Road	Maidstone	Pipe collapse adjacent to property No.46. Crew required to dig down and replace.	Investigation works undertaken. BT to attend after identifying their assets through the drainage system. Awaiting dates.
Gabriel's Hill	Maidstone	Non-Return Valves required to be fitted outside shops due to strong sewage smell.	Works completed.
Church Road	Boughton Malherbe	Consistent Leak from carriageway, water test has shown chlorine.	Southeast Water investigating further.
Woodcock Lane	Boughton Malherbe	Regular flooding, water bypassing ditches.	Works are in conjunction with issue on Church Road.
Goudhurst Road	Marden	Damaged Ironworks	Works programmed for 6.12.2022 to 8.12.2022
Chart Road	Sutton Valence	Pipe collapse outside property title "Pendine"	Works programmed for 6.3.2023 to 8.3.2023